

Schena, Cristeen

From: Turin, David
Sent: Thursday, July 09, 2015 8:04 AM
To: 'Aram Varjabedian'; 'david.burns@state.ma.us'; 'Dow, James'; 'Frank Cavaleri'; 'Joyce, Ryan (FWE)'
Cc: 'Kevin Stetson'
Subject: RE: 9 Highland Ave, Hull, MA - MA0101231

Hi Aram,

Thank you for your email. I'll let you know if I need more information after I see the written report.

Dave

David Turin
U.S. Environmental Protection Agency
Water Technical Unit
Mail code OES04-3
5 Post Office Square - Suite 100
Boston MA 02109 - 3912

Tel. (617) 918-1598 :: Fax (617) 918-0598
turin.david@epa.gov

From: Aram Varjabedian [mailto:avarjabedian@woodardcurran.com]
Sent: Wednesday, July 08, 2015 12:15 PM
To: david.burns@state.ma.us; Turin, David; Dow, James; Frank Cavaleri; Joyce, Ryan (FWE)
Cc: Kevin Stetson
Subject: 9 Highland Ave, Hull, MA - MA0101231

We responded to a call at 9 Highland Ave. 7:30am On July 2, 2015. The investigation discovered a wet area in driveway area and in road. Manholes upstream and downstream of the affected area were found to be flowing. A push camera was sent up the sewer line and encountered a blockage. The "Sewer Tech" vactor/jet truck was dispatched to the area at approximately 12 noon, and could not jet through the blockage. Due to the late time in the day, the co-ordination for the excavation of the area was set up for 7/3/15. Flow of sewage through the main was verified again and found to be good. The only observations noted the small wet areas, as seen earlier in the day.

The blockage was caused by a collapsed pipe and the pipe was repaired. There was no overflow into any storm drains or water body. I will send you the completed SSO form. We have updated our reporting process, and will initiate a phone call upon learning of a sewage issue, where any sewage release to the ground is seen. This will be followed by an email. The SSO form will follow.

I apologize for the delay. Please let me know if you need any other information at this time.

Sincerely,
Aram

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue | Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS